

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DC982		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner ANDERS INC.						Phone # (414)542-0246		1. Well Location				Fire # (if avail.)							
Mailing Address 21420 W GREENFIELD						Town of DELAFIELD						Street Address or Road Name and Number N-11 W-29962 KINGSWAY							
City NEW BERLIN				State WI		Zip Code 53146													
County Waukesha		Co. Permit #		Notification #		Completed 10-18-1990		Subdivision Name DOVER BAY				Lot # Block #							
Well Constructor (Business Name) ED KRANZ				Lic. # 340		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address 14325 W HAMPTON RD BROOKFIELD WI 53005-1622				Well Plan Approval #		NE NW Section Township Range or Govt Lot # 26 7 N 18 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW HOME											
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #		Common Well #		Specific Capacity 4		Construction Type Drilled													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
10		Surface		20		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		C G STONEY CLAY Y SAND @ GRAVEL L LIMEROCK		Surface 25 57 317		25 57 317							
6		20		317															
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		20 ft. below ground surface				10 in. above grade					
6		NEW BLACK STEEL T.C.-19.45# PER FT. ASTM A-53 GR.B NKK				Surface		57		10. Pump Test Pumping level 25 ft. below surface Pumping at 20 GP for 4 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?							
Method																			
Kind of Sealing Material PUDDLED CLAY				From (ft.) Surface		To (ft.) 20		# Sacks Cement											
PUDDLED CLAY												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												EK						12-29-1990	
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		10	Clearwater Sump		20
			Septic or Holding, or POWTS Tank		60

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Well Construction	07/31/1991	WELL IS 12" ABOVE GRADE-DONT EXTEND WELL

Created On: 10-21-1991

Updated On: 10-21-1991

Review Status: