

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DE124		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner KENS MOBILE HOMES						Phone # (608)734-3298		1. Well Location				Fire # (if avail.)		
Mailing Address HWY 171/35						Town of S CENTRAL FREEMAN						Street Address or Road Name and Number		
City FERRYVILLE				State WI		Zip Code 54628								
County Crawford		Co. Permit #		Notification #		Completed 06-24-1991		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) KIRSCHBAUM, DONALD C				Lic. # 170		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code		
Address 16189 DUTCH HILL RD BOSCOBEL WI 53805-9144				Well Plan Approval #		NE NE		Section 10		Township 10 N		Range 6 W		
				Approval Date (mm-dd-yyyy)		or Govt Lot #		10		10 N		6 W		
Hicap Permanent Well #		Common Well #		Specific Capacity 4		2. Well Type New Well								
3. Well serves 1 # of MOBILE HOME Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		of previous unique well # _____ constructed in _____						
						Hicap Property ? No								
Heat Exchange ___ # of drillholes						Hicap Potable ?		Reason for replaced or reconstructed well ? 						
						Construction Type Drilled								
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
10		Surface		92		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								
6		92		120										
8. Geology														
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
☐ X				SAND @ CLAY				Surface		20				
☐ N				SAND ROCK				20		120				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		NEW BLACK STEEL PE 18.97 PSI-1200 A-120 CB@KSUPPLY SAWHILL PIPE				Surface		92						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
7. Grout or Other Sealing Material														
Method CEMENT PUMP														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						
CLAY				Surface		8								
CEMENT				8		92		34						
9. Static Water Level														
80 ft. below ground surface														
10. Pump Test														
Pumping level 82 ft. below surface														
Pumping at 8 GP for 3 Hrs.														
Pumping Method ?														
11. Well Is														
12 in. above grade														
Developed ? Yes														
Disinfected ? Yes														
Capped ? Yes														
12. Notified Owner of need to fill & seal ?														
Filled & Sealed Well(s) as needed?														
13. Constructor / Supervisory Driller														
DCK								Lic #		Date Signed 06-04-1992				
Drill Rig Operator								Lic or Reg #		Date Signed 06-04-1992				
DDK														

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		20

Comment:

Created On: 06-19-1992

Updated On: 06-19-1992

Review Status: