Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DM951

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FERN W BRADY	Phone #: (715)723-1008
Mailing Address: 111 KIMBERLY DR	
City: CHIPPEWA FALLS	State: WI — Zip Code: 54729
County: Chippewa	Co. Permit #: W04572 — Notification #: — Completed: 12-01-1990
Well Constructor (Business Name): WETTSTEIN ROBERT	Lic. #: 506 — Facility ID # (Public Wells):
Address: RT 2 BOX 130C EAU CLAIRE WI 54703	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.1

1. Well Location

Town of LAFAYETTE

Fire # (if avail.):

Street Address or Road Name and Number: RIDGEWAY DR

Subdivision Name	Lot #	Block #
CSM 887	00001	

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NE	SE	Section	Township	Range
or Govt Lot #		5	28 N	7 W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?: NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	89

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		S	G	BROWN SAND AND GRAVEL	Surface	46
T		S	C	BROWN SAND AND CLAY	46	56
T		C		BROWN CLAY	56	88
G		Q		GRAY GRANITE	88	89

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL THREADED @ CUPPLED 20 LBS PER FT ASTMA53 B 1780 PSI VALLEY STEEL PIPE	Surface	89
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

9. Static Water Level

34 ft. below ground surface

10. Pump Test

Pumping level 65 ft. below surface

Pumping at 3 GP for 8 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RW		12-12-1990
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MW		12-12-1990

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Landfill		600
Building Overhang		12	Septic or Holding, or POWTS Tank		50

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Landfill Variance	07/03/1990	600' TO LANDFILL

Created On: 04-04-1991 Updated On: 04-04-1991 Review Status: