Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DN247

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BARB KOCH			Phone #: (608)981-2465
Mailing Address: 3RD AVE			
City: PORTAGE	State: WI	Zip Code: 53901	
County: Marquette	Co. Permit #:	Notification #:	Completed: 10-10-1991

Well Constructor (Business Name): WALKER, KARL M	Lic. #: 103	Facility ID # (Public Wells):
Address: 3199 8TH AVE WISCONSIN DELLS WI 53965-8998		Well Plan Approval #: Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.7

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of DOUGLAS

Fire # (if avail.):

Street Address or Road Name and Number: 3RD AVE

Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:
NE NE or Govt Lot #:	Section: 32	Township: 14 N	Range: 8 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	79

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 6in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y		SAND @ GRAVEL	Surface	26
G		C		GRAY CLAY	26	62
	N	S		FINE SAND	62	70
	M	S		MED. SAND	70	79

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	US STEEL 6.625 A-53 .280 WALL WELDED	Surface	75
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	JOHNSON STAINLESS WIRE WRAP 12 SLOT	75	79

7. Grout or Other Sealing Material
Method NONE

9. Static Water Level
5 ft. below ground surface

10. Pump Test
Pumping level 40 ft. below surface
Pumping at 25 GP for 2.5 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
KMW		10-24-1991
Drill Rig Operator	Lic or Reg #	Date Signed
BW		10-24-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		200	Building Overhang		15
			Septic or Holding, or POWTS Tank		75

Comment:

Created On: 06-19-1992 Updated On: 06-19-1992 Review Status: