Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DN250

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LON KLIMKE			Phone #: (608)589-5567
Mailing Address: 6TH RD			
City: OXFORD	State: WI	Zip Code: 53952	
County: Marquette	Co. Permit #:	Notification #:	Completed: 09-01-1991

Well Constructor (Business Name): WALKER, KARL M	Lic. #: 103	Facility ID # (Public Wells):	
Address: 3199 8TH AVE WISCONSIN DELLS WI 53965-8998		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.4	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of OXFORD

Fire # (if avail.):

Street Address or Road Name and Number: 6TH RD

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code:

SW SW or Govt Lot #	Section: 13	Township: 15 N	Range: 8 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Jetted

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	66

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y		SAND @ GRAVEL	Surface	23
G		C		GRAY CLAY	23	57
	M	S		MED SAND	57	66

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	SAWHILL .154 WALL ASTM A-589 R&D 2 THREAD	Surface	63
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
1.25	STAINLESS MESH 60 GA	63	66

7. Grout or Other Sealing Material
Method

9. Static Water Level
18 ft. below ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 18 GP for 1.5 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
KW		10-24-1991
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
KW		10-24-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Building Overhang		6
			Septic or Holding, or POWTS Tank		40

Comment:

Created On: 06-19-1992 Updated On: 06-19-1992 Review Status: