

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DN251		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner KENNETH BENTLY						Phone # (414)297-2440		1. Well Location				Fire # (if avail.)							
Mailing Address 209 LAKE ST						Town of MECAN						Street Address or Road Name and Number HWY 23							
City MONTELLO				State WI		Zip Code 53949													
County Marquette		Co. Permit #		Notification #		Completed 10-18-1991		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) WALKER, KARL M				Lic. # 103		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code					
Address 3199 8TH AVE WISCONSIN DELLS WI 53965-8998				Well Plan Approval #				°N		°W		NE NW Section Township Range or Govt Lot # 32 16 N 11 E							
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #				Common Well #		Specific Capacity 0.4				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? HOME Construction Type Drilled									
3. Well serves 1 # of				Hicap Well ? No															
Private, potable				Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		76		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 6in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						H C Y S G C G Z S I N S G A S G		HEAVY CLAY SAND (YELLOW @ WHITE) CLAY (GRAY) SANDY CLAY W/GRAVEL (GRAY) SANDSTONE (WHITE) SAND, LG. STONES, SOME CLAY COARSE SAND/MED TO FINE GRAVEL		Surface 3 25 51 58 63 72 76			
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		2.5 ft. above ground surface				40 in. above grade					
6		US STEEL 6 5/8 A53 .280 WALL WELDED				Surface		72		10. Pump Test Pumping level 40 ft. below surface Pumping at 15 GP for 2.5 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
6		TRL JOHNSON WIRE WRAP 15 SLT STAINLESS				72		76											
7. Grout or Other Sealing Material Method												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes							
								13. Constructor / Supervisory Driller				Lic #		Date Signed					
								KW						10-24-1991					
								Drill Rig Operator				Lic or Reg #		Date Signed					
								BW						10-24-1991					

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		8

Comment:

Created On: 06-19-1992

Updated On: 07-11-2023

Review Status: