Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DN251

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KENNETH BENTLY			Phone #: (414)297-2440
Mailing Address: 209 LAKE ST			
City: MONTELLO	State: WI	Zip Code: 53949	
County: Marquette	Co. Permit #:	Notification #:	Completed: 10-18-1991

Well Constructor (Business Name): WALKER, KARL M	Lic. #: 103	Facility ID # (Public Wells):	
Address: 3199 8TH AVE WISCONSIN DELLS WI 53965-8998		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.4	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of MECAN

Fire # (if avail.):

Street Address or Road Name and Number: HWY 23

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code:

NE NW or Govt Lot #:	Section: 32	Township: 16 N	Range: 11 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	76

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 6in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	H	C		HEAVY CLAY	Surface	3
Y		S		SAND (YELLOW @ WHITE)	3	25
G		C		CLAY (GRAY)	25	51
G		Z	S	SANDY CLAY W/GRAVEL (GRAY)	51	58
I		N		SANDSTONE (WHITE)	58	63
		S	G	SAND, LG. STONES, SOME CLAY	63	72
	A	S	G	COARSE SAND/MED TO FINE GRAVEL	72	76

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	US STEEL 6 5/8 A53 .280 WALL WELDED	Surface	72
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	TRL JOHNSON WIRE WRAP 15 SLT STAINLESS	72	76

9. Static Water Level
2.5 ft. above ground surface

10. Pump Test
Pumping level 40 ft. below surface
Pumping at 15 GP for 2.5 Hrs.
Pumping Method ?

11. Well Is
40 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
KW		10-24-1991
Drill Rig Operator	Lic or Reg #	Date Signed
BW		10-24-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		8

Comment:

Created On: 06-19-1992 Updated On: 07-11-2023 Review Status: