

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DN315		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner JOE BERAN					Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address N3076 BOND RD					Town of MEDBRAY		Street Address or Road Name and Number BOND RD							
City LA CROSSE			State WI		Zip Code 54601		Subdivision Name				Lot #		Block #	
County La Crosse		Co. Permit # W05534		Notification #		Completed 12-01-1991		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code		
Well Constructor (Business Name) HOLLER, NORMAN				Lic. # 252		Facility ID # (Public Wells)		NW NE Section Township Range or Govt Lot # 25 16 N 7 W		Well Plan Approval #				
Address 4049 STATE RD LA CROSSE WI 54601				Approval Date (mm-dd-yyyy)		2. Well Type New Well								
Hicap Permanent Well #				Common Well #		Specific Capacity 0.6		Reason for replaced or reconstructed well ?						
3. Well serves 1 # of				Hicap Well ? No		Construction Type Drilled								
Private, potable				Hicap Property ? No		of previous unique well # constructed in								
Heat Exchange ____ # of drillholes				Hicap Potable ?		Reason for replaced or reconstructed well ?								
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock								
8		Surface		83		Rotary - Mud Circulation								
6		83		215		Rotary - Air								
						Rotary - Air & Foam								
						Drill-Through Casing Hammer								
						Reverse Rotary								
						Cable-tool Bit 8in. dia...								
						Dual Rotary								
						Temp. Outer Casing ____ in. dia								
						Removed? ____ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)			To (ft.)					
C			CLAY			Surface			17					
H			SHALE-ROCK			17			34					
N			SAND-ROCK			34			215					
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level		11. Well Is		
6		BLACK, PLAIN-END WTA USA WT 18.97 ASTM A53				Surface		84		162 ft. below ground surface		16 in. above grade		
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test		Developed ? Yes		
										Pumping level 180 ft. below surface		Disinfected ? Yes		
										Pumping at 10 GP for 10 Hrs.		Capped ? Yes		
										Pumping Method ?				
7. Grout or Other Sealing Material														
Method MACHINE														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ?				
CEMENT				Surface		0		20		Filled & Sealed Well(s) as needed?				
13. Constructor / Supervisory Driller														
Lic #								Date Signed						
NH								12-10-1991						
Drill Rig Operator								Lic or Reg #				Date Signed		

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		76	Building Overhang		16
Building Drain - Sanitary		50	Sewer - Building Sanitary		56
			Septic or Holding, or POWTS Tank		65

Comment:

Created On: 06-09-1992

Updated On: 06-09-1992

Review Status: