Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DN894

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LEON ETTEN			Phone #: (715)839-8231
Mailing Address: 2159 1/2 BRACKETT AV			
City: EAU CLAIRE	State: WI	Zip Code: 54701	
County: Eau Claire	Co. Permit #: W05879	Notification #	Completed: 06-01-1992

Well Constructor (Business Name): OLSON, DANIEL B	Lic. #: 352	Facility ID # (Public Wells)	
Address: 3188 SUNDET RD EAU CLAIRE WI 54703-0346		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 1.5	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of LUDINGTON

Fire # (if avail.)

Street Address or Road Name and Number: NORTH SHORE DR

Subdivision Name	Lot #	Block #
FIRST ASSESORS PLAT AT LAKE EA	00001	3

Latitude / Longitude in Decimal Degree (DD) °N °W — Method Code

NW	SE	Section	Township	Range
or Govt Lot #		5	26 N	6 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
COTTAGE

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	30
6	30	81

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 10in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		TOPSOIL	Surface	1
		S		SAND	1	9
	S	N		SOFT SAND ROCK	9	12
	H	N		FIRM SAND ROCK	12	81

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL T@C NEW BLACK 19.45 #PER FT. 280 WALL ASTMA53 SAWHILL STEEL	Surface	44
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
37 ft. below ground surface

10. Pump Test
Pumping level 50 ft. below surface
Pumping at 20 GP for 3 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method CEMENT PUMP

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	3	
NEAT CEMENT	3	30	15

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DBO		06-02-1992
Drill Rig Operator	Lic or Reg #	Date Signed
DBO		06-02-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		95	Shoreline/Pool		248
Building Drain - Sanitary		24	Sewer - Building Sanitary		24
Building Overhang		24	Septic or Holding, or POWTS Tank		26

Comment:

Created On: 06-24-1992 Updated On: 06-24-1992 Review Status: