

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DO297		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner AL FISCHER						Phone # (715)832-7115		1. Well Location				Fire # (if avail.)					
Mailing Address OLSON RD						Town of BRUNSWICK						Street Address or Road Name and Number OLSON ROAD					
City EAU CLAIRE				State WI		Zip Code 54701											
County Eau Claire		Co. Permit # W03990		Notification #		Completed 10-16-1990		Subdivision Name			Lot #		Block #				
Well Constructor (Business Name) ROBERT WETTSTEIN				Lic. # 506		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code					
Address RT 2 BOX 130C EAU CLAIRE WI 54703-9802				Well Plan Approval #		NW SE		Section 14		Township 26 N		Range 10 W					
				Approval Date (mm-dd-yyyy)		or Govt Lot #		Township 26 N		Range 10 W							
Hicap Permanent Well #			Common Well #			Specific Capacity			2. Well Type New Well								
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		Reason for replaced or reconstructed well ? NEW HOME									
						Hicap Property ? No											
Hicap Potable ?						Construction Type Drilled											
						4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method						8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		42		Rotary - Mud Circulation Rotary - Air <u>Yes</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? ___ depth ft. (If NO explain on back side)		T S C LIGHT BROWN SAND @ CLAY		Surface		13					
6		42		145													
6		42		145													
6		42		145													
6		42		145													
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		89 ft. below ground surface							
6		NEW STEEL THREADED AND COUPLED 20#/FT ASTM A53 B1780 PSI VALLEY STEEL PIPE				Surface		42		18 in. above grade							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test							
6		NEW STEEL THREADED AND COUPLED 20#/FT ASTM A53 B1780 PSI VALLEY STEEL PIPE				Surface		42		Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Disinfected ? Yes							
6		NEW STEEL THREADED AND COUPLED 20#/FT ASTM A53 B1780 PSI VALLEY STEEL PIPE				Surface		42		Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 89 ft. below surface							
6		NEW STEEL THREADED AND COUPLED 20#/FT ASTM A53 B1780 PSI VALLEY STEEL PIPE				Surface		42		Pumping at 12 GP for 4 Hrs.							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping Method ?							
6		NEW STEEL THREADED AND COUPLED 20#/FT ASTM A53 B1780 PSI VALLEY STEEL PIPE				Surface		42		Filled & Sealed Well(s) as needed? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		12. Notified Owner of need to fill & seal ?							
6		NEW STEEL THREADED AND COUPLED 20#/FT ASTM A53 B1780 PSI VALLEY STEEL PIPE				Surface		42		Filled & Sealed Well(s) as needed? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		13. Constructor / Supervisory Driller							
6		NEW STEEL THREADED AND COUPLED 20#/FT ASTM A53 B1780 PSI VALLEY STEEL PIPE				Surface		42		Lic #							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Date Signed							
6		NEW STEEL THREADED AND COUPLED 20#/FT ASTM A53 B1780 PSI VALLEY STEEL PIPE				Surface		42		11-11-1990							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Drill Rig Operator							
6		NEW STEEL THREADED AND COUPLED 20#/FT ASTM A53 B1780 PSI VALLEY STEEL PIPE				Surface		42		Lic or Reg #							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Date Signed							
6		NEW STEEL THREADED AND COUPLED 20#/FT ASTM A53 B1780 PSI VALLEY STEEL PIPE				Surface		42		11-11-1990							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	60	Building Overhang		12
Building Drain - Sanitary	>	10	Sewer - Building Sanitary	>	10
			Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 03-13-1991

Updated On: 03-13-1991

Review Status: