Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DO653

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCOTT @ LISA COVERT			Phone #
Mailing Address: SELWOOD RD			
City: PRAIRIE DU SAC	State: WI	Zip Code: 53578	
County: Columbia	Co. Permit #	Notification #	Completed: 04-23-1992

Well Constructor (Business Name): SMITH, WILLIAM J	Lic. #: 518	Facility ID # (Public Wells)	
Address: E10704B HWY 136 BARABOO WI 53913		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 3.6	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of WEST POINT

Fire # (if avail.)

Street Address or Road Name and Number: SELWOOD RD

Subdivision Name: SELWOOD FARMS	Lot #: 00002	Block #

Latitude / Longitude in Decimal Degree (DD) °N °W
Method Code

SE SE or Govt Lot #	Section: 19	Township: 10 N	Range: 7 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	152

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 10in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		X	G	SAND CLAY GRAVEL	Surface	68
		Y		SAND GRAVEL	68	152

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18.97 A53 WELD JOINT SAWHILL PIPE	Surface	149
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	25 SLOT STAINLESS	149	152

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	20	

9. Static Water Level
86 ft. below ground surface

10. Pump Test
Pumping level 91 ft. below surface
Pumping at 18 GP for 12 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
NONE IN AREA

13. Constructor / Supervisory Driller	Lic #	Date Signed
WS		04-23-1992
Drill Rig Operator	Lic or Reg #	Date Signed
WS		04-23-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		13	Downspout/Yard Hydrant		11

Comment:

Created On: 06-03-1992 Updated On: 06-03-1992 Review Status: