

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DO653		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner SCOTT @ LISA COVERT						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address SELWOOD RD						Town of WEST POINT							
City PRAIRIE DU SAC						State WI		Zip Code 53578					
County Columbia		Co. Permit #		Notification #		Completed 04-23-1992		Subdivision Name SELWOOD FARMS				Lot # 00002	
Well Constructor (Business Name) SMITH, WILLIAM J				Lic. # 518		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code	
Address E10704B HWY 136 BARABOO WI 53913				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SE SE		Section 19		Township 10 N	
								Range 7 E					
Hicap Permanent Well #				Common Well #		Specific Capacity 3.6		2. Well Type New Well					
Reason for replaced or reconstructed well ?				NEW HOME									
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No		Construction Type Drilled					
Heat Exchange ___ # of drillholes				Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock										
10 Surface 20													
6 20 152			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)										
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.) To (ft.)				
X G			SAND CLAY GRAVEL						Surface 68				
Y			SAND GRAVEL						68 152				
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)							
6		STEEL 18.97 A53 WELD JOINT SAWHILL PIPE				Surface 149							
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)							
6		25 SLOT STAINLESS				149 152							
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material			From (ft.) To (ft.) # Sacks Cement										
CLAY SLURRY			Surface 20										
9. Static Water Level													
86 ft. below ground surface													
10. Pump Test													
Pumping level 91 ft. below surface													
Pumping at 18 GP for 12 Hrs.													
Pumping Method ?													
11. Well Is													
16 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
NONE IN AREA													
13. Constructor / Supervisory Driller						Lic #		Date Signed					
WS								04-23-1992					
Drill Rig Operator						Lic or Reg #		Date Signed					
WS								04-23-1992					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		13	Downspout/Yard Hydrant		11

Comment:

Created On: 06-03-1992

Updated On: 06-03-1992

Review Status: