Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DO772

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DAVID JELINCK			Phone #: (715)284-9070
Mailing Address: 617 N 10TH ST			
City: BLACK RIVER FALLS	State: WI	Zip Code: 54615	
County: Jackson	Co. Permit #:	Notification #:	Completed: 10-02-1991
Well Constructor (Business Name): DITTER WELL DRILLING INC	Lic. #: 412	Facility ID # (Public Wells):	
Address: PO BOX 176 LOYAL WI 54446-0176		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.5	

1. Well Location

Town of ADAMS

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name	Lot #	Block #
	00101	

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

NW or Govt Lot #	NW	Section	Township	Range
		16	21 N	4 W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?: NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	7
8.75	7	138
6	138	155

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Yes — Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	7
N	SANDSTONE	7	119
H	SHALE	119	134
N	SANDSTONE	134	155

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.97 LB. NEW STEEL ASTM - A53B WELDED SAWHILL	Surface	138
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

108 ft. below ground surface

10. Pump Test

Pumping level 130 ft. below surface

Pumping at 10 GP for 1 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method GROUT PUMP

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	138	30

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DK		11-06-1991
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		120

Type	Qualifier	Distance
Building Overhang		18
Septic or Holding, or POWTS Tank		35

Comment:

Created On: 01-03-1992 Updated On: 01-03-1992 Review Status: