Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DO774

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DARLENE DOUTHITT	Phone #: (715)748-4979
Mailing Address: W5378 WHITTLESEY AVE	
City: MEDFORD	State: WI — Zip Code: 54451
County: Clark	Co. Permit #:
Notification #	Completed: 09-30-1991
Well Constructor (Business Name): DITTER WELL DRILLING INC	Lic. #: 412
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: PO BOX 176 LOYAL WI 54446-0176	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 0.3	

1. Well Location

Fire # (if avail.)

Town of GREEN GROVE

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD) — °N °W — Method Code

or Govt Lot #	SE SE	Section	Township	Range
		29	28 N	1 W

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

OTHER SOURCE SHUT OFF

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	40
6	40	55

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		CLAY	Surface	24
	X	N	C	SANDSTONE @ CLAY LAYERED	24	39
		N		SANDSTONE	39	49
		Q		GRANITE	49	55

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.97# NEW STL ASTM-A53B WELDED SAWHILL	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

10 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 8 GP for 2 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method: GROUT PUMP

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL SLURRY	Surface	8	
NEAT CEMENT	8	40	8

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DK		11-06-1991
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60

Type	Qualifier	Distance
Building Overhang		10
Septic or Holding, or POWTS Tank		47

Comment:

Created On: 01-03-1992 Updated On: 01-03-1992 Review Status: