Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DO792

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JOANNE FALCON			Phone #
Mailing Address: PO BOX 321			
City: BLACK RIVER FALLS	State: WI	Zip Code: 54615	
County: Jackson	Co. Permit #	Notification #	Completed: 11-15-1991

Well Constructor (Business Name): DITTER WELL DRILLING INC	Lic. # 412	Facility ID # (Public Wells)	
Address: PO BOX 176 LOYAL WI 54446-0176		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 1.2	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of BROCKWAY

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD) °N °W

Method Code

NW or Govt Lot #	NE	Section	Township	Range
		31	21 N	3 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW RESIDENCE

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	13
8.75	13	30
6	30	50

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	13
		N		SANDSTONE	13	50

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL 18.97 LB ASTM-A53B SAWHILL WELDED	Surface	30
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
10 ft. below ground surface

10. Pump Test
Pumping level 20 ft. below surface
Pumping at 12 GP for 1 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method GROUT PUMP

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL SLURRY	Surface	7	
NEAT CEMENT	7	30	7

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DK		12-04-1991
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		15

Comment:

Created On: 01-07-1992 Updated On: 01-07-1992 Review Status: