

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DO792		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner JOANNE FALCON						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address PO BOX 321						Town of BROCKWAY							
City BLACK RIVER FALLS						State WI		Zip Code 54615					
County Jackson		Co. Permit #		Notification #		Completed 11-15-1991		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) DITTER WELL DRILLING INC				Lic. # 412		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code	
Address PO BOX 176 LOYAL WI 54446-0176				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 31 21 N 3 W		2. Well Type New Well				of previous unique well # constructed in	
Hicap Permanent Well #		Common Well #		Specific Capacity 1.2		Reason for replaced or reconstructed well ? NEW RESIDENCE							
3. Well serves 1 # of Private, potable				Hicap Well ? No		Construction Type Drilled							
Heat Exchange ___ # of drillholes				Hicap Property ? No									
				Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock										
10 Surface 13			Rotary - Mud Circulation										
8.75 13 30			<u>Yes</u> Rotary - Air										
6 30 50			Rotary - Air & Foam										
			Drill-Through Casing Hammer										
			Reverse Rotary										
			Cable-tool Bit ___ in. dia...										
			Dual Rotary										
			<u>Yes</u> Temp. Outer Casing 10in. dia										
			<u>Yes</u> Removed? ___ depth ft. (If NO explain on back side)										
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.) To (ft.)				
S			SAND						Surface 13				
N			SANDSTONE						13 50				
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)							
6		NEW STEEL 18.97 LB ASTM-A53B SAWHILL WELDED				Surface 30							
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)							
7. Grout or Other Sealing Material													
Method GROUT PUMP													
Kind of Sealing Material		From (ft.) To (ft.)		# Sacks Cement									
DRILL SLURRY		Surface 7											
NEAT CEMENT		7 30		7									
9. Static Water Level													
10 ft. below ground surface												11. Well Is	
10. Pump Test												16 in. above grade	
Pumping level 20 ft. below surface												Developed ? Yes	
Pumping at 12 GP for 1 Hrs.												Disinfected ? Yes	
Pumping Method ?												Capped ? Yes	
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller													
DK												Lic # Date Signed	
Drill Rig Operator												12-04-1991	
Lic or Reg # Date Signed													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		15

Comment:

Created On: 01-07-1992

Updated On: 01-07-1992

Review Status: