Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DO868

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DELL RAWHOUSE			Phone #: (715)723-0307
Mailing Address: 2580 AEBLEY RD			
City: CHIPPEWA FALLS	State: WI	Zip Code: 54729	
County: Eau Claire	Co. Permit #: W05551	Notification #	Completed: 10-26-1990

Well Constructor (Business Name): ROBERT WETTSTEIN	Lic. #: 506	Facility ID # (Public Wells)
Address: RT 2 BOX 130C EAU CLAIRE WI 54703-9802		Well Plan Approval #
		Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity

1. Well Location

Town of WASHINGTON

Fire # (if avail.)

Street Address or Road Name and Number: HIGHWAY 93

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

SW SE or Govt Lot #	Section: 3	Township: 26 N	Range: 9 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: NEED FOR WATER

Construction Type: Drilled

3. Well serves 1 # of COMMERCIAL

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	42
6	42	85

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Yes Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes Temp. Outer Casing 10in. dia
- Yes Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		S		BROWN SAND	Surface	9
T		N		LIGHT BROWN SANDROCK	9	85

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL THREADED @ CUPPLED 20LBS PER FT ASTMA53 B 1780 PSI VALLEY STEEL PIPE	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method PRESSURE TREMIE LINE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLEAR CEMENT AN	Surface	42	12

9. Static Water Level

35 ft. below ground surface

10. Pump Test

Pumping level 35 ft. below surface

Pumping at 18 GP for 3 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RW		11-11-1990
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MW		11-11-1990

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		89
Building Drain - Sanitary	>	10
Building Overhang		15
Sewer - Building Sanitary	>	10
Septic or Holding, or POWTS Tank		85

Comment:

Created On: 03-27-1991 Updated On: 03-27-1991 Review Status: