Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DO886

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JOSEPH RUF			Phone #: (715)723-2413
Mailing Address: RT 5			
City: CHIPPEWA FALLS	State: WI	Zip Code: 54729	
County: Chippewa	Co. Permit #: W04571	Notification #	Completed: 11-21-1990

Well Constructor (Business Name): WETTSTEIN ROBERT	Lic. #: 506	Facility ID # (Public Wells)	
Address: RT 2 BOX 130C EAU CLAIRE WI 54703		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 9	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of EAGLE POINT

Fire # (if avail.)

Street Address or Road Name and Number
CO 178

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD) °N °W
Method Code

SE SE or Govt Lot #	Section: 20	Township: 29 N	Range: 8 W

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEED FOR WATER

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	65.5

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T S G	BROWN SAND @ GRAVEL	Surface	65.5

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL THREADED @ COUPLED 20 LBS PER FT ASTMA53 B 1780 PSI VALLEY STEEL PIPE	Surface	63
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	JOHNSON STAINLESS STEEL	62.5	65.5

7. Grout or Other Sealing Material
Method

9. Static Water Level
41 ft. below ground surface

10. Pump Test
Pumping level 43 ft. below surface
Pumping at 18 GP for 6 Hrs.
Pumping Method ?

11. Well Is
13 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
WELL STILL IN USE

13. Constructor / Supervisory Driller	Lic #	Date Signed
RW		12-12-1990
Drill Rig Operator	Lic or Reg #	Date Signed
MW		12-12-1990

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70

Type	Qualifier	Distance
Building Overhang		13
Septic or Holding, or POWTS Tank		60

Comment:

Created On: 04-01-1991 Updated On: 04-01-1991 Review Status: