

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DO887		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner LARRY SCHEMENSLE Phone # (715)874-6685						1. Well Location				Fire # (if avail.)			
Mailing Address RT 2 BOX 323A						Town of WHEATON							
City ELK MOUND State WI Zip Code 54739						Street Address or Road Name and Number LANE ROAD							
County Chippewa		Co. Permit # W04573		Notification #		Completed 11-27-1990		Subdivision Name		Lot # Block #			
Well Constructor (Business Name) WETTSTEIN ROBERT				Lic. # 506		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W		Method Code			
Address RT 2 BOX 130C EAU CLAIRE WI 54703				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 2 28 N 10 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW HOME					
				Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #		Common Well #		Specific Capacity 18									
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)	
6 Surface 47						T S G BROWN SAND @ GRAVEL				Surface 40			
						T G BROWN GRAVEL				40 47			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)		9. Static Water Level		11. Well Is			
6		NEW STEEL THREADED @ COUPLED 20 LBS PER FT ASTMA53 B 1780 PSI VALLEY STEEL PIPE				Surface 47		22 ft. below ground surface		16 in. above grade			
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)		10. Pump Test		Developed ? Yes Disinfected ? Yes Capped ? Yes			
								Pumping level 23 ft. below surface Pumping at 18 GP for 15 Hrs. Pumping Method ?					
7. Grout or Other Sealing Material Method												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes	
13. Constructor / Supervisory Driller								Lic #		Date Signed			
RW										12-12-1990			
Drill Rig Operator								Lic or Reg #		Date Signed			
MW										12-12-1990			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Building Overhang		25
Building Drain - Sanitary	>	25	Sewer - Building Sanitary	>	25
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 04-01-1991

Updated On: 04-01-1991

Review Status: