

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DP561		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner LEONARD NEVERMAN						Phone # (715)329-5414		1. Well Location				Fire # (if avail.)							
Mailing Address W10497 HWY 8						Town of DUNBAR						10497							
City DUNBAR						State WI		Zip Code 54156				Street Address or Road Name and Number HWY 8							
County Marinette		Co. Permit #		Notification #		Completed 03-23-1992		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) JOHNSON, MAURICE				Lic. # 664		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address RT 1 BOX 2A PEMBINE WI 54156-9801				Well Plan Approval #		NE NE		Section 4		Township 36 N		Range 19 E							
Hicap Permanent Well #				Common Well #		Specific Capacity		2. Well Type New Well				of previous unique well # constructed in							
3. Well serves 1 # of HOME				Hicap Well ? No		Hicap Property ? No		Reason for replaced or reconstructed well ?				Construction Type Drilled							
Private, potable				Hicap Potable ?															
Heat Exchange ___ # of drillholes																			
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		20		Yes Rotary - Mud Circulation						S		SAND		Surface		5	
6		20		300		Rotary - Air						Z		CLAY @ GRAVEL		5		97	
						Rotary - Air & Foam						Q		GRANITE ROCK		47		300	
						Drill-Through Casing Hammer													
						Reverse Rotary													
						Cable-tool Bit ___ in. dia...													
						Dual Rotary													
						Temp. Outer Casing ___ in. dia													
						Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		50 ft. below ground surface				12 in. above grade					
6		VALLEY STEEL 280W ASTMA53 TESTED 1780 WELDED JOINT				Surface		47		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 250 ft. below surface				Disinfected ? Yes					
										Pumping at 1.5 GP. for 4 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method												Filled & Sealed Well(s) as needed?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement				13. Constructor / Supervisory Driller				Lic #		Date Signed	
DRILLING MUD				Surface		20						MJ						03-23-1992	
												Drill Rig Operator				Lic or Reg #		Date Signed	
												MJ						03-23-1992	

4a. Potential Contamination SourcesIs the well located in floodplain ? No**Comment:**

PACKER SETTING 80' WATER PRESSURE TO START 1000 LBS WENT DOWN TO 300 LBS AFTER 2000 GAL OF WATER PUMPED IN

Rehab Type	Rehab Date	Result Text
Hydrofracture		BEFORE 0 AFTER 1.5 GPM AT 250'

Created On: 06-29-1992

Updated On: 06-29-1992

Review Status: