

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DP649		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner JERRY STERSTRUP						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address W212 S7354 ANNES WAY						City of MUSKEGO						Street Address or Road Name and Number W212 S7354 ANNE WAY									
City MUSKEGO				State WI		Zip Code 53150		Subdivision Name				Lot #		Block #							
County Waukesha		Co. Permit #		Notification #		Completed 05-18-1992		Latitude / Longitude in Decimal Degree (DD) 42.9113 °N -88.1798 °W				Method Code GCD013									
Well Constructor (Business Name) MORSE, RICHARD				Lic. # 619		Facility ID # (Public Wells)		SE NW Section Township Range or Govt Lot # 7 5 N 20 E		2. Well Type New Well LM507 replaces this well of previous unique well # constructed in											
Address S78 W32552 SUGDEN RD MUKWONAGO WI 53149				Well Plan Approval #		Approval Date (mm-dd-yyyy)		Reason for replaced or reconstructed well ? WATER													
Hicap Permanent Well #				Common Well #		Specific Capacity		Construction Type Drilled													
3. Well serves 1 # of Private, potable Heat Exchange ____ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method												8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
6		Surface		35		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)				G GRAVEL P HARD PAN S SAND		Surface 30 33 35									
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		20 ft. below ground surface				17 in. above grade							
6		STEEL 19 LBS ASTM-A-53 SAWHILL WELDED				Surface		33		10. Pump Test Pumping level 20 ft. below surface Pumping at 10 GP for 4 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?											
5		SLOT-STAINLESS				33		35													
7. Grout or Other Sealing Material Method												13. Constructor / Supervisory Driller				Lic #		Date Signed			
												DB						05-19-1992			
												Drill Rig Operator				Lic or Reg #		Date Signed			
												DB						05-19-1992			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		105	Downspout/Yard Hydrant		23
Building Overhang		16	Septic or Holding, or POWTS Tank		75

Comment:

Created On: 06-19-1992

Updated On: 07-11-2019

Review Status: