

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DP920		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner DAN KOMEL						Phone # (414)728-8804		1. Well Location				Fire # (if avail.)											
Mailing Address RFD						Town of DELAVAN																	
City DELAVAN						State WI		Zip Code 53115															
County Walworth		Co. Permit #		Notification #		Completed 12-16-1991		Subdivision Name LAKE DELAVAN HIGHLANDS				Lot # 00128											
								Block #															
Well Constructor (Business Name) HARMON FINLEY				Lic. # 218		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code											
								°N °W															
Address RT 1 BOX 302 WALWORTH WI 53184-9754				Well Plan Approval #		SW SW		Section 32		Township 2 N		Range 16 E											
				Approval Date (mm-dd-yyyy)		or Govt Lot #																	
Hicap Permanent Well #		Common Well #		Specific Capacity 1.5		2. Well Type New Well		of previous unique well # constructed in															
						Reason for replaced or reconstructed well ?																	
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No		Construction Type Drilled															
Heat Exchange ___ # of drillholes				Hicap Potable ?																			
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
8		Surface		6								X G		CLAY, SAND, GRAVEL		Surface		14					
5.56		6		103		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 5.56in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						Y		SAND, GRAVEL		14		43					
												X G		CLAY SAND GRAVEL		43		89					
												Y		SAND GRAVEL		89		107					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		1 ft. above ground surface				12 in. above grade									
5.56		ASTM A-53 15LB 5.56X.253 1950 PSI				Surface		103		10. Pump Test				Developed ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 7 ft. below surface				Disinfected ? Yes									
4		JOHNSON				103		107		Pumping at 12 GP for 24 Hrs.				Capped ? Yes									
										Pumping Method ?													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?									
Method																							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?													
BENSEAL				Surface		0				Yes													
13. Constructor / Supervisory Driller								Lic #		Date Signed													
HF										12-24-1991													
Drill Rig Operator								Lic or Reg #		Date Signed													
WS										12-24-1991													

4a. Potential Contamination Sources

Is the well located in floodplain ?

Type	Qualifier	Distance
Collector Sewer - San or Storm		51

Comment:

Created On: 03-17-1992

Updated On: 03-17-1992

Review Status: