Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DP921

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MIKE DOLAN			Phone #
Mailing Address: W2227 A LK LORIAN RD			
City: DELAVAN	State: WI	Zip Code: 53115	
County: Walworth	Co. Permit #	Notification #	Completed: 01-31-1992

1. Well Location

Fire # (if avail.)

Town of RICHMOND

Street Address or Road Name and Number: W2227A

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
HARMON FINLEY	218	

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

NW	NE	Section	Township	Range
or Govt Lot #		18	3 N	15 E

Well Plan Approval #

Address: RT 1 BOX 302
WALWORTH WI 53184-9754

Approval Date (mm-dd-yyyy)

2. Well Type New Well

of previous unique well # constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.3

Reason for replaced or reconstructed well ?

NEW HOME

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
5.56	Surface	130

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 5in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		CLAY	Surface	29
		Y		SAND, GRAVEL	29	101
		C	G	CLAY, GRAVEL	101	115
		S	G	SAND, GRAVEL	115	130

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5.56	ASTM A-53 15 LB 5 9/16 X .258 1950 PSI	Surface	127
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	JOHNSON 12 SLOT	127	130

9. Static Water Level

70 ft. below ground surface

10. Pump Test

Pumping level 110 ft. below surface

Pumping at 10 GP for 24 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method POURED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENASEAL	Surface	0	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
HF		02-07-1992
Drill Rig Operator	Lic or Reg #	Date Signed
WS		02-07-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65	Septic or Holding, or POWTS Tank		35

Comment:

Created On: 03-18-1992 Updated On: 03-18-1992 Review Status: