

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DP921		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner MIKE DOLAN						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address W2227 A LK LORIAN RD						Town of RICHMOND						Street Address or Road Name and Number W2227A							
City DELAVAN				State WI		Zip Code 53115													
County Walworth		Co. Permit #		Notification #		Completed 01-31-1992		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) HARMON FINLEY				Lic. # 218		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code					
Address RT 1 BOX 302 WALWORTH WI 53184-9754				Well Plan Approval #				°N		°W		NW NE Section Township Range or Govt Lot # 18 3 N 15 E							
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #				Common Well #		Specific Capacity 0.3				2. Well Type New Well									
Reason for replaced or reconstructed well ? NEW HOME				Construction Type Drilled															
3. Well serves 1 # of								Hicap Well ? No											
Private, potable								Hicap Property ? No											
Heat Exchange ___ # of drillholes				Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
5.56		Surface		130		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 5in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				C CLAY		Surface		29					
5.56		ASTM A-53 15 LB 5 9/16 X .258 1950 PSI		Surface		127		Y SAND, GRAVEL		29		101							
4		JOHNSON 12 SLOT		127		130		C G CLAY, GRAVEL		101		115							
S G SAND, GRAVEL		115		130															
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		70 ft. below ground surface				12 in. above grade					
5.56		ASTM A-53 15 LB 5 9/16 X .258 1950 PSI				Surface		127		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 110 ft. below surface				Disinfected ? Yes					
4		JOHNSON 12 SLOT				127		130		Pumping at 10 GP for 24 Hrs.				Capped ? Yes					
7. Grout or Other Sealing Material												Pumping Method ?							
Method POURED												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
BENASEAL				Surface		0													
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												HF						02-07-1992	
												Drill Rig Operator				Lic or Reg #		Date Signed	
												WS						02-07-1992	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65	Septic or Holding, or POWTS Tank		35

Comment:

Created On: 03-18-1992

Updated On: 03-18-1992

Review Status: