

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DP922		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner GEORGE BAER					Phone # (708)250-8122		1. Well Location				Fire # (if avail.)										
Mailing Address 1360 FOXDALE DR					Town of LINN		Street Address or Road Name and Number														
City ADDISON			State IL		Zip Code 60101		Subdivision Name LAKE GENEVA BEACH					Lot # 00178		Block #							
County Walworth			Co. Permit #		Notification #		Completed 12-20-1991		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code								
Well Constructor (Business Name) HARMON FINLEY					Lic. # 218		Facility ID # (Public Wells)		SW or Govt Lot #		SW 11		Section 1		Township 1 N		Range 17 E				
Address RT 1 BOX 302 WALWORTH WI 53184-9754					Well Plan Approval #		Approval Date (mm-dd-yyyy)		2. Well Type Replacement					of previous unique well #			constructed in				
Hicap Permanent Well #			Common Well #			Specific Capacity 0.2			Reason for replaced or reconstructed well ? OLD POINT DRY					Construction Type Drilled							
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes					Hicap Well ? No Hicap Property ? No Hicap Potable ?		Reason for replaced or reconstructed well ? OLD POINT DRY														
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method																					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole										Lower Open Bedrock					
5.56		Surface		76		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 5in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen																					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8. Geology											
5.56		ASTM A-53 15 LB 5 9/16 X .258 1950 PSI				Surface		73		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
4		JOHNSON 12 SLOT				73		76				C		CLAY				Surface		28	
												S G		SAND, GRAVEL				28		76	
7. Grout or Other Sealing Material																					
Method POURED																					
Kind of Sealing Material				From (ft.)		To (ft.)		11. Well Is													
BENSEAL				Surface		0		12. Static Water Level													
10. Pump Test																					
Pumping level 52 ft. below surface Pumping at 10 GP for 24 Hrs. Pumping Method ?																					
12. Notified Owner of need to fill & seal ?																					
Filled & Sealed Well(s) as needed?																					
13. Constructor / Supervisory Driller																					
HF																					
Drill Rig Operator																					
WS																					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 03-18-1992

Updated On: 03-18-1992

Review Status: