

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DQ232		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner JOHN K MCCORMICK						Phone # (414)783-6307		1. Well Location				Fire # (if avail.)			
Mailing Address 14360 NEWELL DR								Town of FLAMBEAU							
City BROOKFIELD						State WI		Zip Code 53005							
County		Co. Permit #		Notification #		Completed 07-09-1991		Subdivision Name				Lot #		Block #	
Price								Latitude / Longitude in Decimal Degree (DD)				Method Code			
Well Constructor (Business Name) DAVID DAVIS						Lic. # 642		Facility ID # (Public Wells)				°N °W			
Address HCR3 BOX 42 PHILLIPS WI 54555-9504						Well Plan Approval #		NW NE		Section 31		Township 38 N		Range 2 W	
						Approval Date (mm-dd-yyyy)		or Govt Lot #							
Hicap Permanent Well #				Common Well #		Specific Capacity 1.4		2. Well Type New Well							
								of previous unique well # constructed in							
Reason for replaced or reconstructed well ?															
3. Well serves 1 # of Private, potable						Hicap Well ? No									
Heat Exchange ___ # of drillholes						Hicap Property ? No									
						Hicap Potable ?		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		108.5		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
Y				SAND AND GRAVEL				Surface		23					
P G				HARD PAN @ ROCKS				23		106					
Y				SAND AND GRAVEL				106		108.5					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		NEW BLK STEEL 18.97 P.E. COUNCE TENN A53				Surface		108.5							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method															
9. Static Water Level															
48 ft. below ground surface															
10. Pump Test															
Pumping level 55 ft. below surface															
Pumping at 10 GP for 8 Hrs.															
Pumping Method ?															
11. Well Is															
24 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed?															
13. Constructor / Supervisory Driller															
DD				Lic #				Date Signed							
								07-11-1991							
Drill Rig Operator				Lic or Reg #				Date Signed							
DD								07-11-1991							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		40	Privy		80

Comment:

Created On: 12-10-1991

Updated On: 12-10-1991

Review Status: