Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DQ234

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROMAN ZELHOFER	Phone #: (414)235-6606
Mailing Address: 1100 HERITAGE TRAIL	
City: OSHKOSH	State: WI — Zip Code: 54904
County: Ashland	Co. Permit #: — Notification #: — Completed: 09-03-1991
Well Constructor (Business Name): DAVID DAVIS	Lic. #: 642 — Facility ID # (Public Wells):
Address: HCR3 BOX 42 PHILLIPS WI 54555-9504	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.1

1. Well Location
Town of MORSE
Fire # (if avail.):
Street Address or Road Name and Number:
Subdivision Name: — Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code:
SE NE or Govt Lot #: — Section: 25 — Township: 44 N — Range: 3 W

2. Well Type New Well
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	200

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R		S		SAND (ED	Surface	23
R		S	C	SANDY LOAM RED	23	45
		P	G	HARD PAN-ROCKS-8 INCH OPPOXT	45	70
	X	Q		RED @ BLK GRANITE	70	200

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLK STEEL 18.97 P.E. STEL PIPE ASTM A53	Surface	70
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
18 ft. below ground surface

10. Pump Test
Pumping level 75 ft. below surface
Pumping at 5 GP for 15 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DD		09-03-1991
Drill Rig Operator	Lic or Reg #	Date Signed
DD		09-03-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		7	Privy		75

Comment:

Created On: 12-10-1991 Updated On: 12-10-1991 Review Status: