

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DQ234		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner ROMAN ZELHOFER						Phone # (414)235-6606		1. Well Location				Fire # (if avail.)							
Mailing Address 1100 HERITAGE TRAIL						Town of MORSE						Street Address or Road Name and Number							
City OSHKOSH				State WI		Zip Code 54904													
County Ashland		Co. Permit #		Notification #		Completed 09-03-1991		Subdivision Name			Lot #		Block #						
Well Constructor (Business Name) DAVID DAVIS				Lic. # 642		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code								
Address HCR3 BOX 42 PHILLIPS WI 54555-9504				Well Plan Approval #		SE NE		Section 25		Township 44 N		Range 3 W							
				Approval Date (mm-dd-yyyy)		or Govt Lot #		Range 3 W		Range 3 W									
Hicap Permanent Well #		Common Well #		Specific Capacity 0.1		2. Well Type New Well													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		of previous unique well # _____ constructed in _____											
						Hicap Property ? No													
Heat Exchange ___ # of drillholes						Hicap Potable ?		Reason for replaced or reconstructed well ?											
						Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		200		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		R S SAND (ED) Surface 23 R S C SANDY LOAM RED 23 45 P G HARD PAN-ROCKS-8 INCH OPPOXT 45 70 X Q RED @ BLK GRANITE 70 200		R S SAND (ED) Surface 23 R S C SANDY LOAM RED 23 45 P G HARD PAN-ROCKS-8 INCH OPPOXT 45 70 X Q RED @ BLK GRANITE 70 200		R S SAND (ED) Surface 23 R S C SANDY LOAM RED 23 45 P G HARD PAN-ROCKS-8 INCH OPPOXT 45 70 X Q RED @ BLK GRANITE 70 200		R S SAND (ED) Surface 23 R S C SANDY LOAM RED 23 45 P G HARD PAN-ROCKS-8 INCH OPPOXT 45 70 X Q RED @ BLK GRANITE 70 200					
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		18 ft. below ground surface				18 in. above grade					
6		BLK STEEL 18.97 P.E. STEL PIPE ASTM A53				Surface		70		10. Pump Test Pumping level 75 ft. below surface Pumping at 5 GP for 15 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
7. Grout or Other Sealing Material Method												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?							
								13. Constructor / Supervisory Driller				Lic #		Date Signed					
								DD						09-03-1991					
								Drill Rig Operator				Lic or Reg #		Date Signed					
								DD						09-03-1991					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		7	Privy		75

Comment:

Created On: 12-10-1991

Updated On: 12-10-1991

Review Status: