

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DQ904		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner ROBERT SCHULTZ						Phone # (414)521-0637		1. Well Location				Fire # (if avail.)			
Mailing Address W2415 HEATHER ST						Town of ASHIPUN						Street Address or Road Name and Number			
City OCONOMOWOC				State WI		Zip Code 53066									
County Dodge		Co. Permit #		Notification #		Completed 12-11-1990		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) KUCK FREDERICK F				Lic. # 593		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.22295 °N -88.51599 °W				Method Code GPS008	
Address W1603 HWY MM NEOSHO WI 53059				Well Plan Approval #				NW NW		Section 29		Township 9 N		Range 17 E	
				Approval Date (mm-dd-yyyy)				2. Well Type New Well							
Hicap Permanent Well #				Common Well #		Specific Capacity 15				Reason for replaced or reconstructed well ? NEW HOME					
3. Well serves 1 # of Private, potable						Hicap Well ? No				Construction Type Drilled					
Heat Exchange ___ # of drillholes						Hicap Property ? No									
Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
10 Surface 20			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)												
6 2 92															
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
C CLAY				Surface				30							
S H VERY SOFT SHALE				30				61							
L LIME STONE				61				92							
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		.280 TC ASTM A53 19.45 L.T.V. SEIDEMAN				Surface		61							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material		Method				Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement			
CLAY SLURRY		Surface				20		11. Well Is		12 in. above grade					
9. Static Water Level		41 ft. below ground surface				10. Pump Test		Developed ? Yes		Disinfected ? Yes		Capped ? Yes			
Pumping level 42 ft. below surface		Pumping at 15 GP for 5 Hrs.				Pumping Method ?		12. Notified Owner of need to fill & seal ?		Filled & Sealed Well(s) as needed?					
13. Constructor / Supervisory Driller		Lic #				Date Signed		FK		12-11-1990					
Drill Rig Operator		Lic or Reg #				Date Signed		PK		12-11-1990					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		12	Collector Sewer - San or Storm		52
Clearwater Sump		15	Foundation Drain to Clearwater		12
			Sewer - Building Sanitary		25

Comment:

Created On: 07-12-1991

Updated On: 08-19-2022

Review Status: