Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DQ907

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CHARLES BOGAN	Phone #: (414)521-0637
Mailing Address: W699 ROLEFSON RD	
City: RUBICON	State: WI — Zip Code: 53078
County: Dodge	Co. Permit #: — Notification #: — Completed: 12-24-1990
Well Constructor (Business Name): KUCK FREDERICK F	Lic. #: 593 — Facility ID # (Public Wells):
Address: W1603 HWY MM, NEOSHO WI 53059	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 4

1. Well Location

Town of ASHIPPUN

Fire # (if avail.):

Street Address or Road Name and Number: SAME

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 43.25969 °N -88.43042 °W — Method Code: GPS008

NE SW or Govt Lot #: — Section: 12 — Township: 9 N — Range: 17 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	8
6	8	82

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 10in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		P		HARD PAN	Surface	7
		S	G	SAND @ GRAVEL	7	30
		P		HARDPAN	30	60
		S	G	SAND @ GRAVEL	60	82

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	19.45 .280 T C ASTM A53 LTV SEIDEMAN	Surface	79
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	3' JOHNSON SCREEN SS	79	82

9. Static Water Level

60 ft. below ground surface

10. Pump Test

Pumping level 65 ft. below surface

Pumping at 20 GP for 5 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	8	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
FK		12-24-1990
Drill Rig Operator	Lic or Reg #	Date Signed
PK		12-24-1990

4a. Potential Contamination Sources Is the well located in floodplain ? Yes

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Foundation Drain to Clearwater		12
Building Overhang		12	Sewer - Building Sanitary		35
Clearwater Sump		25	Septic or Holding, or POWTS Tank		48

Comment:

Created On: 03-25-1991 Updated On: 08-19-2022 Review Status: