Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DQ913

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DON CHAPMAN	Phone #: (414)474-4444
Mailing Address: W930 HWY O	
City: OCONOMOWOC	State: WI Zip Code: 53066
County: Dodge	Co. Permit #:
Notification #	Completed: 02-06-1991
Well Constructor (Business Name): KUCK, FREDERICK F	Lic. #: 593
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: W1603 HWY MM NEOSHO WI 53059-9728	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 1.3	

1. Well Location

Town of ASHIPPUN

Fire # (if avail.)

Street Address or Road Name and Number: W930 HWY O

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 43.2169 °N -88.44215 °W

Method Code: GPS008

SE	NE	Section	Township	Range
or Govt Lot #		26	9 N	17 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: WASH GOLF CARTS

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	10
6	10	40

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 10in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	10
S	SAND	10	35
Y	SAND @ GRAVEL	35	40

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	19.45 280 T@C ASTM A53 LTV SEIDEMAN	Surface	37
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	SS JOHNSON SCREEN	37	40

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	10	

9. Static Water Level

8 ft. below ground surface

10. Pump Test

Pumping level 16 ft. below surface

Pumping at 10 GP M for 6 Hrs.

Pumping Method ?

11. Well Is

24 in. below grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
FK		02-20-1991
Drill Rig Operator	Lic or Reg #	Date Signed
PK		02-20-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		6

Comment:

Created On: 10-08-1991 Updated On: 02-27-2024 Review Status: