

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DR256		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner M. @ I. BANK OF MADISON						Phone # (608)283-5905		1. Well Location				Fire # (if avail.)							
Mailing Address 1 W MAIN ST						Town of KOSHKONONG						Street Address or Road Name and Number N1807 HWY 12							
City MADISON				State WI		Zip Code 53705													
County Jefferson		Co. Permit #		Notification #		Completed 03-14-1992		Subdivision Name			Lot #		Block #						
Well Constructor (Business Name) VOGEL, ALBIN				Lic. # 634		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.9056 °N -88.8267 °W			Method Code GCD013						
Address RT 1 JEFFERSON WI 53549-9801				Well Plan Approval #				NW SE Section Township Range or Govt Lot # 10 5 N 14 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? INADEQUATE WATER SUPPLY									
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #			Common Well #			Specific Capacity 2			Construction Type Drilled										
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)								
10 Surface 21			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				I TOP SOIL		Surface		1								
6 21 173							C CLAY		1		42								
							L LIME ROCK		42		149								
							N SAND ROCK		149		173								
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)		17 ft. below ground surface				14 in. ____ grade							
6		NEW STEEL PLAIN END WITH WELDED JONTS WEIGHING 18.97 LBS. PER FOOT ASTM A-53 US MADE BY SAWHILL				Surface		42				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)		Pumping level 23 ft. below surface Pumping at 12 GP for 4 Hrs. Pumping Method ?											
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes							
Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement CLAY SLURRY Surface 21																			
Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement CLAY SLURRY Surface 21												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												AV				Lic or Reg #		Date Signed	
												Drill Rig Operator				Lic or Reg #		Date Signed	
												AVMV				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		95	Sewer - Building Sanitary		115
			Septic or Holding, or POWTS Tank		87

Comment:

COULDN'T LOCATE WELL AT HIGHEST POINT ON PROPERTY THAT WOULD HAVE MADE IT TOO CLOSE TO NEIGHBORS SE PTIC SYSTEM

Created On: 06-29-1992

Updated On: 09-26-2019

Review Status: