

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DS171		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner RONALD L ANDERSON						Phone # (404)928-4799		1. Well Location				Fire # (if avail.)							
Mailing Address 2060 CANDLEWOOD CT						Town of PEPIN						Street Address or Road Name and Number HWY 35							
City MARIETTA				State GA		Zip Code 30066													
County Pepin		Co. Permit #		Notification #		Completed 05-04-1992		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) SCHULTZ, CARL F				Lic. # 365		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address 29 E 10TH ST BUFFALO COCHRANE WI 54622-7335				Well Plan Approval #		SW SE		Section 30		Township 23 N		Range 14 W							
				Approval Date (mm-dd-yyyy)		or Govt Lot #		2. Well Type Replacement		of previous unique well #		constructed in							
Hicap Permanent Well #		Common Well #		Specific Capacity 1.2		Reason for replaced or reconstructed well ? OLD WELL DRIED UP													
3. Well serves 1 # of Private, potable				Hicap Well ? No		Construction Type Drilled													
Heat Exchange ___ # of drillholes				Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8		Surface		9		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 8in. dia Removed? ___ depth ft. (If NO explain on back side)				Q S		SAND CAVING BROWN SOFT		Surface		89			
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is									
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		39 ft. below ground surface				12 in. above grade					
4		NEW BL STEEL T@C A53B-E 11.00# LTV				Surface		86		10. Pump Test Pumping level 49 ft. below surface Pumping at 12 GP for 4 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
3.75		STAINLESS STEEL 12 SLOT				86		89											
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method												Filled & Sealed Well(s) as needed? PUMP INSTALLER WILL							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
PUDDLED SLURRY				Surface		9													
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												CFS						05-05-1992	
												Drill Rig Operator				Lic or Reg #		Date Signed	
												CFS						05-05-1992	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		10	Privy	>	80

Comment:

Created On: 06-03-1992

Updated On: 06-03-1992

Review Status: