Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DS171

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RONALD L ANDERSON	Phone #: (404)928-4799
Mailing Address: 2060 CANDLEWOOD CT	
City: MARIETTA	State: GA Zip Code: 30066
County: Pepin	Co. Permit #:	Notification #:	Completed: 05-04-1992
Well Constructor (Business Name): SCHULTZ, CARL F	Lic. #: 365	Facility ID # (Public Wells):
Address: 29 E 10TH ST BUFFALO COCHRANE WI 54622-7335	Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.2

1. Well Location

Town of PEPIN

Fire # (if avail.):

Street Address or Road Name and Number: HWY 35

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

SW	SE	Section	Township	Range
or Govt Lot #		30	23 N	14 W

2. Well Type Replacement

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?: OLD WELL DRIED UP

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	9
4	9	89

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....

Yes Temp. Outer Casing 8in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Q S	SAND CAVING BROWN SOFT	Surface	89

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BL STEEL T@C A53B-E 11.00# LTV	Surface	86
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3.75	STAINLESS STEEL 12 SLOT	86	89

9. Static Water Level

39 ft. below ground surface

10. Pump Test

Pumping level 49 ft. below surface

Pumping at 12 GP for 4 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PUDDLED SLURRY	Surface	9	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

PUMP INSTALLER WILL

13. Constructor / Supervisory Driller	Lic #	Date Signed
CFS		05-05-1992
Drill Rig Operator	Lic or Reg #	Date Signed
CFS		05-05-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		10	Privy	>	80

Comment:

Created On: 06-03-1992 Updated On: 06-03-1992 Review Status: