Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DS174

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PATRICK ROHN			Phone #: (608)582-4473
Mailing Address: 224 S 7TH			
City: ARCADIA	State: WI	Zip Code: 54612	
County: Trempealeau	Co. Permit #:	Notification #:	Completed: 05-13-1992

Well Constructor (Business Name): SCHULTZ, CARL F	Lic. #: 365	Facility ID # (Public Wells):
Address: 29 E 10TH ST BUFFALO COCHRANE WI 54622-7335		Well Plan Approval #:
		Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 3

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of ARCADIA

Fire # (if avail.):

Street Address or Road Name and Number: MIDDLE RD

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code:

SW	SE	Section	Township	Range
or Govt Lot #		2	20 N	10 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME BEING BUILT

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	14
6	14	145

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 10in. dia...
- Dual Rotary .....
- Yes Temp. Outer Casing 10in. dia
- Yes Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	V	C		CLAY NON CAV. BROWN SOFT	Surface	14
	Q	C	S	CLAY @ SAND CAV. BROWN SOFT	14	27
Y		S		SAND CAV. YELLOW SOFT	27	46
	V	N		SANDSTONE NON CAV. YELLOW SOFT	46	51
	H	N		SANDSTONE NON CAV. YELLOW HARD	51	69
U		H		SHALE NON CAV. BLUE HARD	69	145

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BL STEEL T@C A53B-E 19.45# SAWHILL	Surface	51
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method KEPT WITHIN 9 FT WHILE DRIVING

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PUDDLED CLAY	Surface	14	

9. Static Water Level
94 ft. below ground surface

10. Pump Test
Pumping level 98 ft. below surface
Pumping at 12 GP for 6 Hrs.
Pumping Method ?

11. Well Is
15 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
NONE TO SEAL

13. Constructor / Supervisory Driller	Lic #	Date Signed
CFS		05-14-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
CFS		05-14-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		13	Foundation Drain to Clearwater		14

Comment:

Created On: 06-03-1992 Updated On: 06-03-1992 Review Status: