

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DS174		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner PATRICK ROHN						Phone # (608)582-4473		1. Well Location				Fire # (if avail.)									
Mailing Address 224 S 7TH						Town of ARCADIA															
City ARCADIA						State WI		Zip Code 54612													
County Trempealeau		Co. Permit #		Notification #		Completed 05-13-1992		Subdivision Name				Lot # Block #									
Well Constructor (Business Name) SCHULTZ, CARL F				Lic. # 365		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code									
Address 29 E 10TH ST BUFFALO COCHRANE WI 54622-7335				Well Plan Approval #		SW SE Section Township Range or Govt Lot # 2 20 N 10 W		2. Well Type New Well of previous unique well # constructed in													
Hicap Permanent Well #		Common Well #		Specific Capacity 3		Reason for replaced or reconstructed well ? NEW HOME BEING BUILT															
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
10		Surface		14		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 10in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? ___depth ft. (If NO explain on back side)				V C		CLAY NON CAV. BROWN SOFT		Surface		14					
6		14		145						Q C S		CLAY @ SAND CAV. BROWN SOFT		14		27					
										Y S		SAND CAV. YELLOW SOFT		27		46					
										V N		SANDSTONE NON CAV. YELLOW SOFT		46		51					
										H N		SANDSTONE NON CAV. YELLOW HARD		51		69					
						U H		SHALE NON CAV. BLUE HARD		69		145									
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		94 ft. below ground surface				15 in. above grade							
6		NEW BL STEEL T@C A53B-E 19.45# SAWHILL				Surface		51		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 98 ft. below surface Pumping at 12 GP for 6 Hrs. Pumping Method ?											
7. Grout or Other Sealing Material Method KEPT WITHIN 9 FT WHILE DRIVING														12. Notified Owner of need to fill & seal ?							
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? NONE TO SEAL													
PUDDLED CLAY		Surface		14																	
13. Constructor / Supervisory Driller														Lic #		Date Signed					
CFS																05-14-1992					
Drill Rig Operator														Lic or Reg #		Date Signed					
CFS																05-14-1992					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		13	Foundation Drain to Clearwater		14

Comment:

Created On: 06-03-1992

Updated On: 06-03-1992

Review Status: