Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DS176

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MICHAEL C CHAMBERS			Phone #: (608)248-2006
Mailing Address: 50 N BELVIDERE ST			
City: BUFFALO CITY	State: WI	Zip Code: 54622	
County: Buffalo	Co. Permit #:	Notification #:	Completed: 05-20-1992

Well Constructor (Business Name): SCHULTZ, CARL F	Lic. #: 365	Facility ID # (Public Wells):	
Address: 29 E 10TH ST BUFFALO COCHRANE WI 54622-7335		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 15	

1. Well Location

City of BUFFALO CITY

Fire # (if avail.):

Street Address or Road Name and Number: 50 N BELVIDERE

Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:
NW NE or Govt Lot #:	Section: 7	Township: 20 N	Range: 12 W

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: OLD WELL IN BASEMENT

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	8
4	8	53

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....

Yes Temp. Outer Casing 8in. dia

Yes Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
N	S		SAND NON CAV BLACK SOFT	Surface	5
Q	S		SAND CAV. BROWN SOFT	5	53

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BL STEEL T@C A53-B E 11.00# HKK	Surface	50
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
3.75	STAINLESS STEEL 15 SLOT	50	53

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PUDDLED CUTTINGS	Surface	8	

9. Static Water Level

14 ft. below ground surface

10. Pump Test

Pumping level 15 ft. below surface

Pumping at 15 GP for 4 Hrs.

Pumping Method ?

11. Well Is

15 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

PUMP INSTALLER WILL

13. Constructor / Supervisory Driller	Lic #	Date Signed
CFS		05-21-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
CFS		05-21-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		72
Building Drain - Sanitary	>	25
Building Overhang	>	9
Sewer - Building Sanitary	>	25
Septic or Holding, or POWTS Tank		44

Comment:

Created On: 06-03-1992 Updated On: 06-03-1992 Review Status: