

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DS254		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner TODD PALMER						Phone # (612)933-3223		1. Well Location				Fire # (if avail.)							
Mailing Address 2828 HEDBERG						Town of OAK GROVE													
City MINNETONKA						State MN		Zip Code 55343											
County Pierce		Co. Permit #		Notification #		Completed 03-25-1991		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) MARTELL STEVE PUMPS AND WD INC				Lic. # 105		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address P O BOX 28 SOMERSET WI 54025				Well Plan Approval #		NW SE Section Township Range or Govt Lot # 19 26 N 19 W		2. Well Type New Well of previous unique well # constructed in											
Hicap Permanent Well #				Common Well #		Specific Capacity 2		Reason for replaced or reconstructed well ?											
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock																
10 Surface 60			Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)																
6 60 305																			
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		220 ft. below ground surface				12 in. above grade					
6		19.45# FT ASTMA 53 NEW PRIME T@C				Surface		60		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 225 ft. below surface Pumping at 10 GP for 1 Hrs. Pumping Method ?				Disinfected ? Yes Capped ? Yes					
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?					
Method PUMP																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?									
NEAT CEMENT				Surface		60		15											
13. Constructor / Supervisory Driller														Lic #		Date Signed			
SF																03-29-1991			
Drill Rig Operator														Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Septic or Holding, or POWTS Tank		150

Comment:

Created On: 07-12-1991

Updated On: 07-12-1991

Review Status: