

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DS283		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner LOUISE BRULA						Phone # () 644-5949		1. Well Location				Fire # (if avail.)											
Mailing Address RR 3						Town of THORP						Street Address or Road Name and Number RD AA											
City STANLEY				State WI		Zip Code 54768																	
County Clark		Co. Permit #		Notification #		Completed 11-10-1990		Subdivision Name				Lot #		Block #									
Well Constructor (Business Name) HATFIELD JOHN J				Lic. # 4934		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code											
Address RT 2 STANLEY WI 54768				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SW NW Section Township Range or Govt Lot # 9 29 N 4 W		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? DUG WELL													
Hicap Permanent Well #		Common Well #		Specific Capacity 1																			
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled																	
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method												8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)							
10		Surface		20		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		C N		CLAY SAND ROCK		Surface 40		40 68									
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		30 ft. below ground surface				12 in. above grade									
6		STD BLACK STEEL WELDED PLAIN END .280 WALL 19:49ASTM-A53 CAC. FD. VENEZUELA				Surface		46		10. Pump Test Pumping level 50 ft. below surface Pumping at 20 GP for 1 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)															
7. Grout or Other Sealing Material Method												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement															
CLAY SLURRY				Surface		20																	
												13. Constructor / Supervisory Driller				Lic #		Date Signed					
												JJH						01-03-1991					
												Drill Rig Operator						Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		85	Nonconforming Pit or Alcove		20
Building Overhang		15	Septic or Holding, or POWTS Tank		55

Comment:

Created On: 07-17-1991

Updated On: 07-17-1991

Review Status: