

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DS285		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner LARRY KORN						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address RT 1 COUNTY TRUNK H						Town of WILSON						Street Address or Road Name and Number RIVER ROAD							
City STANLEY				State WI		Zip Code 54768													
County Eau Claire		Co. Permit # W05622		Notification #		Completed 11-12-1990		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) HATFIELD JOHN J				Lic. # 4934		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code					
Address RT 2 STANLEY WI 54768				Well Plan Approval #				°N		°W		SW SW Section Township Range or Govt Lot # 1 27 N 5 W							
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #				Common Well #		Specific Capacity 0.1				2. Well Type New Well									
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?				Reason for replaced or reconstructed well ? WATER FOR HOME											
								Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		20		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				C		CLAY		Surface		20			
6		20		100						S		SAND		20		60			
										D Q C		SOAPROCK RESIDUE CLAY		60		85			
										Q		GRANITE		85		100			
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		20 ft. below ground surface				12 in. above grade					
6		STD BLACK STEEL WELDED PLAIN END .280 WALL 19.49ASTM-A-53 KKH SAWHILL				Surface		71		10. Pump Test Pumping level 80 ft. below surface Pumping at 5 GP for 1 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method												Filled & Sealed Well(s) as needed? WAS NONE							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
CLAY SLURRY				Surface		20				13. Constructor / Supervisory Driller				Lic #		Date Signed			
								JJH						01-08-1991					
								Drill Rig Operator				Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		150	Building Overhang		74
Building Drain - Sanitary		78	Septic or Holding, or POWTS Tank		100

Comment:

Created On: 07-12-1991

Updated On: 07-12-1991

Review Status: