

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DS426		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner GREG RADTKE						Phone # (414)398-3297		1. Well Location				Fire # (if avail.)			
Mailing Address RT 3 BOX 617						Town of MARQUETTE						Street Address or Road Name and Number HWY B			
City MARKESAN				State WI		Zip Code 53946									
County Green Lake		Co. Permit #		Notification #		Completed 01-21-1991		Subdivision Name			Lot #		Block #		
Well Constructor (Business Name) SLAGER LARRY J				Lic. # 140		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code			
Address P O BOX 405 BRANDON WI 53919				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 27 15 N 12 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? NOT ENOUGH WATER							
Approval Date (mm-dd-yyyy)				Hicap Permanent Well #		Common Well #						Specific Capacity 0.9			
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
8.75 Surface 104			Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)												
6 104 139															
8. Geology															
Dia. (in.) From (ft.) To (ft.)			Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.) To (ft.)						
8.75 Surface 104			C			CLAY			Surface 7						
6 104 139			C G			CLAY AND GRAVEL			7 34						
6 104 139			L H			LIMEROCK W/SHALE			34 78						
6 104 139			N			SAND ROCK			78 139						
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 34 ft. below ground surface		11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes			
6		NEW BLACK STEEL 18.97# PER FT 2600 PSI API 52 A53GR B P/E USA SAWHILL				Surface		104							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material												10. Pump Test Pumping level 50 ft. below surface Pumping at 15 GP for 3 Hrs. Pumping Method ?			
Method PRESSURE												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? STILL GOING TO USE			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
MUD AND CUTTINGS				Surface		6		14							
CEMENT				6		104		14							
13. Constructor / Supervisory Driller												Lic #		Date Signed	
LJS												01-21-1991		Drill Rig Operator	
Drill Rig Operator												Lic or Reg #			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Building Overhang		15
			Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 04-03-1991

Updated On: 04-03-1991

Review Status: