

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DS427		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner RANDY @ SUE MEYERS						Phone # (414)748-2541		1. Well Location				Fire # (if avail.)									
Mailing Address W13206 SCANDI RD						Town of RIPON						Street Address or Road Name and Number SCANDI RD									
City RIPON			State WI		Zip Code 54971			Subdivision Name				Lot # 00019		Block #							
County Fond du Lac		Co. Permit #		Notification #		Completed 02-08-1991		Latitude / Longitude in Decimal Degree (DD) 43.82807 °N -88.8218 °W				Method Code GPS008									
Well Constructor (Business Name) SLAGER LARRY J				Lic. # 140		Facility ID # (Public Wells)		NW SW Section Township Range or Govt Lot # 27 16 N 14 E		2. Well Type New Well			of previous unique well # constructed in								
Address P O BOX 405 BRANDON WI 53919				Well Plan Approval #		Approval Date (mm-dd-yyyy)		Reason for replaced or reconstructed well ? NEW HOME													
Hicap Permanent Well #			Common Well #		Specific Capacity 0.3		Construction Type Drilled														
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8.75		Surface		62		Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						LCAY		Surface		7					
6		62		204						C		G		CLAY @ GRAVEL		7		26			
										L				LIMEROCK		26		180			
										N				SANDROCK		180		186			
										L				LIMEROCK		186		204			
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		60 ft. below ground surface				12 in. above grade							
6		NEW BLACK STEEL 18.97#PER FT 2600 PSI API5L A-53GR B P.E. USA SAWHILL				Surface		62		10. Pump Test Pumping level 105 ft. below surface Pumping at 15 GP for 3 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)													
7. Grout or Other Sealing Material Method PRESSURE														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement													
MUD @ CUTTING				Surface		6															
CEMENT				6		62		9													
13. Constructor / Supervisory Driller														Lic #		Date Signed					
LJS																02-08-1991					
Drill Rig Operator														Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	70	Building Overhang		14
			Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 07-15-1991

Updated On: 08-19-2022

Review Status: