

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DS428		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner SALLY FLASCH						Phone # (414)748-3425		1. Well Location				Fire # (if avail.)							
Mailing Address RT 1 BOX 99						Town of GREEN LAKE						Street Address or Road Name and Number LAKEVIEW RD							
City MARKESAN				State WI		Zip Code 53946													
County Green Lake		Co. Permit #		Notification #		Completed 02-14-1991		Subdivision Name			Lot #		Block #						
Well Constructor (Business Name) SLAGER LARRY J				Lic. # 140		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address P O BOX 405 BRANDON WI 53919				Well Plan Approval #		NE NW Section Township Range or Govt Lot # 5 15 N 13 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? OLD WELL HAD ATRAZINE IN											
Approval Date (mm-dd-yyyy)				Hicap Permanent Well #		Common Well #						Specific Capacity 0.8							
3. Well serves 1 # of Private, potable						Hicap Well ? No		Construction Type Drilled											
Heat Exchange ___ # of drillholes						Hicap Property ? No						Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8.75		Surface		210		Yes Rotary - Mud Circulation		Rotary - Air		C G CLAY @ BOULDERS		Surface		18					
6		210		260		Rotary - Air & Foam		Drill-Through Casing Hammer		C G CLAY @ GRAVEL		18		26					
Reverse Rotary		Cable-tool Bit ___ in. dia...		Dual Rotary		Temp. Outer Casing ___ in. dia		Removed? ___ depth ft. (If NO explain on back side)		L LIMEROCK		26		68					
N SANDROCK		68		260															
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		70 ft. below ground surface				12 in. above grade					
6		NEW BLACK STEEL 18.97# PER FT 2600 PSI API5L A-53GR P.E. USA SAWHILL				Surface		210		10. Pump Test Pumping level 90 ft. below surface Pumping at 15 GP for 3 Hrs. Pumping Method ?				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						Disinfected ? Yes					
Capped ? Yes		Filled & Sealed Well(s) as needed?				Yes													
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method PRESSURE												Filled & Sealed Well(s) as needed? Yes							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
MUD @ CUTTINGS				Surface		6		44											
CEMENT				6		20		44											
13. Constructor / Supervisory Driller												Lic #		Date Signed					
LJS												02-15-1991							
Drill Rig Operator												Lic or Reg #		Date Signed					
Date Signed												Date Signed		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	60	Buried Petroleum Tank		105
Building Overhang		26	Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 07-15-1991

Updated On: 07-15-1991

Review Status: