

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DS482		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner MASHUDA CONTRACTORS INC.						Phone # (414)295-3329		1. Well Location				Fire # (if avail.)	
Mailing Address RR 2						Town of PRINCETON							
City PRINCETON						State WI		Zip Code 54968					
County Green Lake		Co. Permit #		Notification #		Completed 07-23-1991		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) LARRY J SLAGER				Lic. # 140		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code	
Address PO BOX 405 BRANDON WI 53919-0405				Well Plan Approval #		SE SW Section Township Range or Govt Lot # 13 16 N 11 E		2. Well Type New Well				of previous unique well # constructed in	
Hicap Permanent Well #		Common Well #		Specific Capacity 0.5		Reason for replaced or reconstructed well ? NEW SHOP @ OFFICE							
3. Well serves 1 # of SHOP @ OFFICE				Hicap Well ? No		Construction Type Drilled							
Private, potable				Hicap Property ? No									
Heat Exchange ___ # of drillholes				Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock										
8.75 Surface 69													
6 69 158			Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)										
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)							
6		NEW BLACK STEEL 18.97#PER FT. 2600 PSI API5L A-53GR. B P.E. U.S.A. SAWHILL				Surface 69							
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)							
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material				From (ft.) To (ft.)		# Sacks Cement							
MUD @ CUTTINGS				Surface 69									
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.) To (ft.)						
S M			SANDY LOAM				Surface 9						
C S			SANDY CLAY				9 21						
Z			CLAY @ GRAVEL				21 52						
C S			SANDY CLAY				52 66						
N			SANDSTONE				66 158						
9. Static Water Level						60 ft. below ground surface		11. Well Is					
10. Pump Test						Pumping level 90 ft. below surface		12 in. above grade					
Pumping at 15 GP for 3 Hrs.						Pumping Method ?		Developed ? Yes					
								Disinfected ? Yes					
								Capped ? Yes					
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller						Lic #		Date Signed					
LJS								07-23-1991					
Drill Rig Operator						Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		12

Comment:

Created On: 11-08-1991

Updated On: 11-08-1991

Review Status: