Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DS483

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: NORWEGIAN WAYS		Phone #: (414)294-3405
Mailing Address: PO BOX 509		
City: GREEN LAKE	State: WI	Zip Code: 54941

County	Co. Permit #	Notification #	Completed
Green Lake			07-22-1991

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
LARRY J SLAGER	140	

Address: PO BOX 405
BRANDON WI 53919-0405

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity
		1.9

3. Well serves 2 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of BROOKLYN

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #
HERITAGE		

Latitude / Longitude in Decimal Degree (DD) °N °W

Method Code

NW NE or Govt Lot #	Section	Township	Range
	20	16 N	13 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOMES

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	69
6	69	158

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	6
X	SAND @ CLAY	6	24
Z	CALY @ GRAVEL	24	67
N	SAND ROCK	67	158

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL 18.97# PER FT 2600 PSI API5L A-53GR. B P.E. U.S.A. SAWHILL	Surface	69
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
MUD @ CUTTING	Surface	69	

9. Static Water Level
52 ft. below ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 15 GP for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	Lic or Reg #	Date Signed
TO		07-22-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		20

Comment:

Created On: 11-08-1991 Updated On: 11-08-1991 Review Status: