

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DS483		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner NORWEGIAN WAYS						Phone # (414)294-3405		1. Well Location				Fire # (if avail.)							
Mailing Address PO BOX 509						Town of BROOKLYN						Street Address or Road Name and Number							
City GREEN LAKE				State WI		Zip Code 54941													
County Green Lake		Co. Permit #		Notification #		Completed 07-22-1991		Subdivision Name HERITAGE			Lot # Block #								
Well Constructor (Business Name) LARRY J SLAGER				Lic. # 140		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code								
Address PO BOX 405 BRANDON WI 53919-0405				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 20 16 N 13 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW HOMES											
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #		Common Well #		Specific Capacity 1.9		Construction Type Drilled													
3. Well serves 2 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8.75		Surface		69		Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		C CLAY X SAND @ CLAY Z CALY @ GRAVEL N SAND ROCK		Surface 6 6 24 24 67 67 158									
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		52 ft. below ground surface				12 in. above grade					
6		NEW BLACK STEEL 18.97# PER FT 2600 PSI API5L A-53GR. B P.E. U.S.A. SAWHILL				Surface		69		10. Pump Test Pumping level 60 ft. below surface Pumping at 15 GP for 2 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?							
Method																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
MUD @ CUTTING				Surface		69				13. Constructor / Supervisory Driller				Lic #		Date Signed			
Drill Rig Operator				Lic or Reg #		Date Signed		TO		07-22-1991									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		20

Comment:

Created On: 11-08-1991

Updated On: 11-08-1991

Review Status: