

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DT179		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner ALLEN HANSEN						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 3839 LAKEVIEW RD						Town of SUAMICO						Street Address or Road Name and Number							
City LITTLE SUAMICO				State WI		Zip Code 54141													
County Brown		Co. Permit #		Notification #		Completed 05-07-1992		Subdivision Name			Lot #		Block #						
Well Constructor (Business Name) HEIM, ERVIN J				Lic. # 551		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code								
Address 4904 CHURCH RD RT 2 NEW FRANKEN WI 54229				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 14 25 N 20 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? HOME											
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #		Common Well #		Specific Capacity 0.5		Construction Type Drilled													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock									Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)			
10 Surface 20			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									S SAND		Surface 15					
6 20 50												C CLAY		15 40					
												L LIMESTONE ROCK		40 50					
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)		25 ft. below ground surface				16 in. above grade						
6			T@C 1945 STEEL PIPE ASTM-A53 SAWHILL				Surface 40		10. Pump Test Pumping level 40 ft. below surface Pumping at 8 GP for 0.25 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes						
Dia. (in.)			Screen type, material & slot size				From (ft.) To (ft.)												
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes							
Method																			
Kind of Sealing Material			From (ft.) To (ft.)		# Sacks Cement														
SLUSHY CLAY			Surface 20																
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												EH						05-26-1992	
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Sewer - Building Sanitary		25
Building Overhang		10	Septic or Holding, or POWTS Tank		35

Comment:

Created On: 06-24-1992

Updated On: 06-24-1992

Review Status: