

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DT182		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner DAVID MARCHAND						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 2740 WOODLAND CT								Town of GREEN BAY							
City GREEN BAY						State WI		Zip Code 54311							
County Brown		Co. Permit #		Notification #		Completed 05-14-1992		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) HEIM, ERVIN J				Lic. # 551		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code			
Address 4904 CHURCH RD RT 2 NEW FRANKEN WI 54229				Well Plan Approval #		NW SE Section Township Range or Govt Lot # 13 25 N 22 E		2. Well Type New Well				of previous unique well # constructed in			
Hicap Permanent Well #		Common Well #		Specific Capacity 1.9		Reason for replaced or reconstructed well ? NEW HOME		Construction Type Drilled							
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
10 Surface 20															
6 50 110			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)												
8. Geology															
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.) To (ft.)									
C CLAY			Surface 57												
S SAND			57 60												
C S CLAY @ SAND			60 90												
P HARDPAN			90 107												
L LIMESTONE ROCK			107 110												
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)									
6		T@C 1945 STEEL PIPE ASTM-A53 SAWHILL				Surface 109									
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)									
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material		From (ft.) To (ft.)		# Sacks Cement											
SLUSHY CLAY		Surface 20													
9. Static Water Level															
1 ft. above ground surface															
10. Pump Test															
Pumping level 15 ft. below surface															
Pumping at 30 GP for 0.25 Hrs.															
Pumping Method ?															
11. Well Is															
24 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller															
Lic #		Date Signed													
EH		05-14-1992													
Drill Rig Operator		Lic or Reg #		Date Signed											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Collector Sewer - San or Storm		55	Sewer - Building Sanitary		25

Comment:

Created On: 06-24-1992

Updated On: 06-24-1992

Review Status: