

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DT183		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A															
Property Owner DON ALLEN					Phone #			1. Well Location				Fire # (if avail.)													
Mailing Address 4510 CLEARWATER TERR					Town of GREEN BAY							Street Address or Road Name and Number 4510 CLEARWATER TERR													
City NEW FRANKEN			State WI		Zip Code 54229																				
County Brown		Co. Permit #		Notification #			Completed 05-01-1992		Subdivision Name			Lot #		Block #											
Well Constructor (Business Name) HEIM, ERVIN J				Lic. # 551		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.6077 °N -87.7863 °W				Method Code GCD013											
Address 4904 CHURCH RD RT 2 NEW FRANKEN WI 54229				Well Plan Approval #				NE SE		Section 26		Township 25 N		Range 22 E											
				Approval Date (mm-dd-yyyy)				or Govt Lot #		26		25 N		22 E											
Hicap Permanent Well #			Common Well #			Specific Capacity 0.3			2. Well Type New Well																
Hicap Well ? No			Hicap Property ? No			Hicap Potable ?			Reason for replaced or reconstructed well ? NEW HOME																
									Construction Type Drilled																
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes																									
4. Potential Contamination Sources - ON REVERSE SIDE																									
5. Drillhole Dimensions and Construction Method																									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock															
10		Surface		20		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
8		20		40														C G		STONELY CLAY		Surface		20	
6		40		85														L		LIMESTONE ROCK		20		85	
6		40		85														L		LIMESTONE ROCK		20		85	
6. Casing, Liner, Screen														8. Geology											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
6		PLAIN END 1897 STEEL PIPE ASTM-A53 SAWHILL				Surface		42		C G L				STONELY CLAY LIMESTONE ROCK				Surface 20		20 85					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)																	
7. Grout or Other Sealing Material														9. Static Water Level				11. Well Is							
Method														20 ft. below ground surface				16 in. above grade							
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		10. Pump Test				Developed ? Yes													
CUTTINGS		Surface		10		7		Pumping level 45 ft. below surface				Disinfected ? Yes													
CEMENT		10		40		7		Pumping at 8 GP for 0.25 Hrs.				Capped ? Yes													
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes														13. Constructor / Supervisory Driller				Lic #		Date Signed					
														EH				05-13-1992		Drill Rig Operator				Lic or Reg #	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Sewer - Building Sanitary		50
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 06-24-1992

Updated On: 11-21-2019

Review Status: