Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DU081

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: STOUT, BRYAN			Phone #: (715)822-2558
Mailing Address: 1796 1 1/2 ST			
City: COMSTOCK	State: WI	Zip Code: 54826	
County: Barron	Co. Permit #:	Notification #:	Completed: 06-16-1999

Well Constructor (Business Name): KENNETH W BEECROFT	Lic. #: 611	Facility ID # (Public Wells):	
Address: 162 310TH AVE FREDERIC WI 54837		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.6	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of CRYSTAL LK

Fire # (if avail.): 1796

Street Address or Road Name and Number: 1 1/2 ST

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 45.467 °N -92.1238 °W
Method Code: GCD013

SE	SW	Section	Township	Range
or Govt Lot #		5	34 N	14 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
WATER DA

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	20
4	20	105

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 8in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
P	HARDPAN	Surface	100
Y	SAND & GRAVEL	100	105

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	IPSCO USA ASTM A53B/ASME SA53B CE 4.500 .237 ARC BUTT WELD P.E. NEW BLK	Surface	102
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	COOK TESCOPING 304 STAINLESS 5 PACK 18	100.5	105

7. Grout or Other Sealing Material

Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL CUTTINGS	Surface	20	

9. Static Water Level
25 ft. below ground surface

10. Pump Test
Pumping level 50 ft. below surface
Pumping at 15 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
STILL USED

13. Constructor / Supervisory Driller	Lic #	Date Signed
KB		06-23-1999
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Shoreline/Pool		150
Building Overhang		3	Septic or Holding, or POWTS Tank		75

Comment:

Created On: 09-17-1999 Updated On: 06-18-2020 Review Status: